



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEx ETL 19.0065X	Page 1 of 4	<u>Certificate history:</u> Issue 0 (2019-12-12)
Status:	Current	Issue No: 1	
Date of Issue:	2023-04-04		
Applicant:	Kurz Instruments 2411 Garden Road Monterey, CA 93940. United States of America. United States of America		
Equipment:	MFT B-Series Mass Flow Meters – Models 454FTB, 454PFTB, 454WGF, 454FTB-WGF, 504FTB, 524FTB, 534FTB, and 544FTB		
Optional accessory:			
Type of Protection:	Flameproof 'db', Increased Safety 'ec'		
Marking:	Ex db IIB + H2 T5...T3 Gb or Ex ec IIC T5...T3 Gc IECEx ETL 19.0065X (For specific temperature ratings refer to Annex on this certificate)		

Approved for issue on behalf of the IECEx
Certification Body:

Todd L. Relyea

Position:

Certification Officer

Signature:
(for printed version)

Date:
(for printed version)

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

Intertek
3933 US Route 11 South
Cortland NY 13045-2995
United States of America

intertek



IECEx Certificate of Conformity

Certificate No.: **IECEx ETL 19.0065X**

Page 2 of 4

Date of issue: 2023-04-04

Issue No: 1

Manufacturer: **Kurz Instruments**
2411 Garden Road
Monterey, CA 93940.
United States of America.
United States of America

Manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

IEC 60079-1:2014 Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
Edition:7.0

IEC 60079-7:2017 Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

[US/ETL/ExTR19.0092/00](#)

[US/ETL/ExTR19.0092/01](#)

Quality Assessment Report:

[US/FMG/QAR09.0003/08](#)



IECEx Certificate of Conformity

Certificate No.: **IECEx ETL 19.0065X**

Page 3 of 4

Date of issue: 2023-04-04

Issue No: 1

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The MFT-B product family measures mass flow of various gases using a constant differential temperature anemometer.

For full equipment description and specific ratings refer to Annex on this certificate.

SPECIFIC CONDITIONS OF USE: YES as shown below:

1. All sealing devices including cable glands, blanking elements, thread adapters and stopping plugs are required to be certified to type of protection Ex 'db' or 'ec' as applicable; be suitable for use in the ambient temperature range and Group of the equipment; carry the same IP rating of the equipment as a minimum and be suitably sized for the cabling which is carried. Installation shall take into account any applicable special conditions for safe use and all relevant installation requirements of IEC 60079-14.
2. External non-metallic materials pose a potential electrostatic charging hazard. To minimize the risk from electrostatic discharge clean only with a damp cloth.
3. Flameproof joints are not intended to be repaired.
4. Each enclosure entry shall have no more than one thread adapter when an adapter is used. A blanking element shall not be used with an adapter.
5. Flow Element Sensor (sting) shall only be installed in areas where the presence of ignitable gas concentrations does not exceed Zone 1 limits.



IECEx Certificate of Conformity

Certificate No.: **IECEx ETL 19.0065X**

Page 4 of 4

Date of issue: 2023-04-04

Issue No: 1

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Added alternate epoxy encapsulant, Resinlab EP1296 Black and updated the related drawings.

Annex:

[SFT-IECEx-OP-19f - Annex for IECEx ETL 19.0065X.pdf](#)



Annex to IECEx Certificate of Conformity

Certificate No:	IECEX ETL 19.0065X	Issue No. 1
Annex No. 1		

Technical Documents			
Title:	Drawing No.:	Rev. Level:	Date:
Electronic Configurations of SC board 420348 and 420380			
MFT B-Series, sensor/electronics configurations (ATEX)	280144	H	11/20/19
Markings/ Labels			
MFT B-Series, Safety Label/Electronics Configurations (ATEX)	280173	H	12/5/19
Power supply			
Schematic, Power Supply (PS) PCB for MFT B series	300168	G	05-17-16
Fab, PCB MFT B-Series AC Power Supply (ATEX)	420349	F	12/5/19
Assembly Drawing (TOP), MFT B-Series MFT AC Power Supply (ATEX)	420350	H	12/5/19
FAB, PCB, Top Insulator Board for Power Supply	170265	E	12/5/19
Off-Line Xfmr Spc. 85-265 VAC to 24 VDC (ATEX)	310028	C	12/5/19
Sensor Control Board Standard			
Schematic, MFT B-Series, Mass Flow Transmitter Electronics (ATEX)	300167	S	9/26/19
FAB, PCB, MFT B-Series, Mass Flow Transmitter electronics	420347	S	8/7/19
Assembly Drawing, MFT B-Series Mass Flow Transmitter Electronics	420348	U	10/18/17
Sensor Control/Transmitter PCB (HART Version)			
Assembly Drawing, MFT B-Series Mass Flow Transmitter (HART) (ATEX)	420380	L	10/18/17
Schematic, MFT B-Series, Mass Flow Transmitter Electronics (HART) (ATEX)	300182	M	9/26/19
FAB, PCB, MFT B-Series, Mass Flow Transmitter (HART)	420379	L	8/7/19
LCD/Keypad			
Schematic, Key Pad/LCD for MFT B-Series (ATEX)	300174	E	4-01-11
Assy, PCB, LCD/KYPD for MFT B-Series (ATEX)	420360	H	6-23-11
Fab PCB, LCD/KYPD for MFT B-Series (ATEX)	420359	G	4/1/11

Certificate issued by:

intertek
Total Quality. Assured.

Intertek Testing Services NA, Inc.
3933 Route 11
Cortland, NY 13045 USA

Page 1 of 5

SFT-IECEX-OP-19f (26 October 2018)



Annex to IECEx Certificate of Conformity

Certificate No:	IECEX ETL 19.0065X	Issue No. 1
Annex No. 1		

Technical Documents			
Title:	Drawing No.:	Rev. Level:	Date:
Transmitter separate terminal block			
Schematic, Transmitter Separate (TS) PCB for MFT B Series	300169	D	3-12-07
Fab. PCB, Transmitter Separate Terminal Block	420351	D	09-6-06
Assembly Drawing,, Transmitter Separate Terminal Block (ATEX)	420352	E	03-12-07
FD2 Sensors			
Safety Approval Drawing Series 544FTB (ATEX)	280127	A	10-10-08
*Safety Approval Drawing Adalet, Series 454FTB -08 thru -16 (ATEX)	280139	J	2/2/22
*Safety Approval Drawing Adalet, Series 504FTB, 534FTB,524FTB, -40 thru -96 (ATEX)	280142	J	2/2/22
*Safety Approval Drawing, Series 454PFTB-16 (ATEX)	280143	L	2/2/22
*Safety Approval Drawing Adalet, Series 454FTB-WGF-12 thru -16 (ATEX)	280168	F	2/2/22
MD Sensors			
*Safety Approval Drawing Adalet, Series 504FTB, 534FTB,524FTB, -4 thru -16 (ATEX)	280140	J	2/2/22
*Safety Approval Drawing Adalet, Series 504FTB, 534FTB,524FTB, -24 thru -32 (ATEX)	280141	J	2/2/22
*Safety Approval Drawing, Adalet, Series 454WGF-16 (ATEX)	280150	D	2/2/22
Fuse			
FUSE, 3.15A, 250V, 5X20mm, SLO-BLO	630081	C	3/12/07
PTS I/O Board			
Schematic for SC TS I/O	300195	B	3-28-13
FAB, PCB SC TS I/O Board (ATEX)	420401	D	5-24-19
Assembly, PCB SC TS I/O Assy	420402	D	5-24-19
PTS I/O Jumper PCB			
Schematic I/O for MFT B – Series	300196	A	3-28-13
FAB, PCB SC Junction Connector Adapter FAB	420403	A1	1/25/17
Assembly, PCB SC Junction Connector Adapter Assy	420404	D	10/4/19
Profibus Board			
Assembly Profibus DP for MFTB (ATEX)	420424	C1	5/28/19
FAB Profibus DP for MTFB (ATEX)	420425	C	7/25/17
Schematic Profibus DP for MFTB Board (ATEX)	300205	B1	22-Aug-16

Certificate issued by:

intertek
Total Quality. Assured.

Intertek Testing Services NA, Inc.
3933 Route 11
Cortland, NY 13045 USA

Page 2 of 5

SFT-IECEX-OP-19f (26 October 2018)



Annex to IECEx Certificate of Conformity

Certificate No:	IECEX ETL 19.0065X	Issue No. 1
Annex No. 1		

Technical Documents			
Title:	Drawing No.:	Rev. Level:	Date:
HART AO2 Board			
Schematic HART AO2 board	300204	A	01-29-15
FAB AO2 board	420421	A	30-Jan15
Assembly Drawings AO2 Board Analog Out 2 for HART Board	420422	A	30-Jan-15
Foundation Fieldbus IO (FF)			
Foundation Fieldbus Connection Board for MFTB SC	300200	1	7-21-16
FAB Foundation Fieldbus for MFTB user connect (ATEX)	420409	A	7-26-16
Assembly Foundation Fieldbus connection board for MFTB SC (ATEX)	420410	A	7-26-16
Fint Fieldbus Adaptor			
Foundation Fieldbus MFTB Interface	300198	A	7-21-16
FAB. PCB, F. Fieldbus MFTB interface Fint carrier board (ATEX)	420405	1	7-26-16
Assembly F. Fieldbus MFTB interface Fint carrier board (ATEX)	420406	1	7-26-16
Polycarbonate enclosure			
N4, MFTB TS AC with LCD Display (ATEX)	700691	B	4-4-14
Wall Mount, N4 Polycarbonate Enclosure (ATEX)	110573	A	4-8-14
Enclosure Lid Label (ATEX)	170301	B	12/19/16
Enclosure Lid Label (ATEX)	170302	A	3/28/13
Subassembly Build Drawings			
Sub Assy, Sensor Control Board to mtg. bracket	700479	H	11-02-10
Sub-assy, MFT B-Series, AC with Display	700480	B	7-14-11
Sub-assy, MFT B-Series, AC w/o Display, Adalet	700481	B	8-31-10
Sub-assy, MFT B-Series, DC with Display	700482	C	7-14-11
Sub-assy, MFT B-Series, Transmitter Separate	700493	B	03-22-07
Sub Assy MFT B-Series, DC w/o Display	700503	A	11-20-06
Sub-Assy MFT B-Series, Adalet, AC with display (ATEX)	700590	D	11/9/17
Sub-Assy MFT B-Series, Adalet, AC w/o display (ATEX)	700591	C	11/9/17
Sub-Assy MFT B-Series, Adalet, DC with display (ATEX)	700592	D	11/9/17

Certificate issued by:

Page 3 of 5



Annex to IECEx Certificate of Conformity

Certificate No:	IECEX ETL 19.0065X	Issue No. 1
Annex No. 1		

Technical Documents			
Title:	Drawing No.:	Rev. Level:	Date:
Sub-Assy MFT B-Series, Adalet, Remote Electronics	700593	B	11/9/17
Sub-Assy MFT B-Series, Adalet, DC w/o display	700654	A	7-28-08
Enclosure modification drawing			
MFTB Housing - Adalet, Double sided Encl. Modified Series XDHM (ATEX)	110535	C	04-23-13
MFTB Remote Adalet Enclosure Modified Series XIHM (ATEX)	110536	C	04-23-13
MFTB Blind Adalet Cover Enclosure Modified Series XIHMFCA (ATEX)	110537	C	04-23-13
MFTB Glass Adalet Lid Modified Enclosure Series XIHMFCA (ATEX)	110538	C	04-23-13
MFTB Custom Cover Adalet Enclosure Series XIHMDCX (ATEX)	110539	C	04-23-13
Modification XIHMDCX, MFT B-Series (ATEX)	110541	B	04-23-13
Stainless Steel enclosure (Ex d)			
Safety Approval MFT B Series Transmitter Separate, SS Enclosure Adalet (ATEX)	280198	D	01-06-17
SS enclosure base (ATEX)	110601	A	10-27-16
SS enclosure tall lid (ATEX)	110602	A	10-27-16
SS enclosure glass lid (ATEX)	110604	A	10-27-16
SS enclosure short lid (ATEX)	110605	A	10-27-16
XIHSX Series SS Instrument housing ATEX/IECEX	280203	A	11-15-16
Production Control Procedures			
*Probe Support Epoxy Seal Potting Procedure (ATEX)	MP-018	F	2/1/2022
B Series Field Wiring Diagram and Installation			
Field Wiring Diagram MFT-B Series (ATEX)	342038	N	12/5/19
Field Wiring Diagram MFT-B Series, TS Configuration (ATEX)	342039	J	9/21/15
Field Wiring Diagram MFT-B Series, TS Polycarbonate Wall Mount (ATEX)	342058	B	12/3/13
Hook-up Label, MFT-B Series (ATEX)	170262	C	3/27/13
Hook-up Label, HART Version MFT-B Series	170304	B	7/20/15

Certificate issued by:

intertek
Total Quality. Assured.

Intertek Testing Services NA, Inc.
3933 Route 11
Cortland, NY 13045 USA

Page 4 of 5

SFT-IECEX-OP-19f (26 October 2018)



Annex to IECEx Certificate of Conformity

Certificate No:	IECEX ETL 19.0065X	Issue No. 1
Annex No. 1		

Technical Documents			
Title:	Drawing No.:	Rev. Level:	Date:
(ATEX)			
B-Series Hardware Guide	368041	N	12/5/19
B-Series Quick Start Guide	368043	C	12/5/19
B-Series Operations Guide	368042	E	
Misc.			
Kurz FD2 and MD Sensor Auto Ignition Testing	430071	A	8/21/08

Required Manufacturer Routine Testing		
Test	Title/Description of Test	Standard and Clause
1	<p>The following routine tests are intended to ensure that the enclosure withstands the pressure and also that it contains no holes or cracks connecting to the exterior.</p> <p>The routine tests include an overpressure test made according to one of the methods described for the type tests in 15.2.3. For equipment intended for use at an ambient temperature below -20 °C, a pressure test at normal ambient temperature is sufficient.</p>	IEC 60079-1, Clause 16.1.1
2	<p>The equipment shall be subjected to the applicable test voltage specified below for at least 1 minute without a breakdown occurring:</p> <p>1) For electrical apparatus with rated voltages not exceeding 90 V peak or with working voltages not exceeding 90 V peak are present: 500 V r.m.s. (+5%/-0)</p> <p>2) DC test voltages are permitted as an alternative to the specified a.c. test voltage and shall be 170% of the specified a.c. r.m.s. test voltage for insulated windings, or 140 % of the specified a.c. r.m.s. test voltage for situations where air or creepage distance is the insulating medium.</p> <p>3) Alternatively, a test can be carried out at 1,2 times the test voltage but maintained for at least 100 ms.</p>	IEC 60079-1, Clause 6.1

Certificate issued by:

intertek
Total Quality. Assured.

Intertek Testing Services NA, Inc.
3933 Route 11
Cortland, NY 13045 USA

Page 5 of 5

SFT-IECEX-OP-19f (26 October 2018)